

# MILLERS IRRIGATION SERVICES

12748 FERNBANK LN  
JACKSONVILLE, FL 32223 USA  
(904) 236-7976  
millersirrigationservices@gmail.com

## INVOICE

BILL TO  
Cottages Of Argyle

INVOICE 12779  
DATE 02/03/2026  
TERMS Net 15  
DUE DATE 02/18/2026

| SERVICE            | DESCRIPTION                     | QTY | RATE   | AMOUNT |
|--------------------|---------------------------------|-----|--------|--------|
| Monthly inspection | Inspection of entire irrigation |     | 500.00 | 500.00 |
| 6 spray head       |                                 | 8   | 20.00  | 160.00 |
| 12 spray head      |                                 | 2   | 25.00  | 50.00  |
| Rotor              |                                 | 3   | 30.00  | 90.00  |
| 1 inch slip fix    |                                 | 1   | 20.00  | 20.00  |
| Tech/helper/hr     |                                 | 3   | 125.00 | 375.00 |

|   |             |                   |
|---|-------------|-------------------|
| System audit.                             | SUBTOTAL    | 1,195.00          |
| Split riser in front of 107 freeze damage | TAX         | 0.00              |
| Spray behind 108 stuck                    | TOTAL       | 1,195.00          |
| Spray in front 106 broke                  |             |                   |
| 12 inch spray in front of 104 leaking     |             |                   |
| Spray in front 301 broke                  |             |                   |
| Spray in front of 1701 broke              |             |                   |
| Spray left 1501 broke                     |             |                   |
| Rotor behind 501 not turning              |             |                   |
| Spray right of 508 stuck                  |             |                   |
| Pipe break in front of 502                |             |                   |
| Spray left of 1201 broke                  |             |                   |
| 12 in spray in front of 1105 broke        |             |                   |
| Spray in front of 1207 broke              |             |                   |
| Rotor in front of 1308 not turning        |             |                   |
| Rotor right 1008 leaking                  |             |                   |
|   | BALANCE DUE | <b>\$1,195.00</b> |

(Zone 7 rotors start at 2:45am which is the rotor zone behind bd 9 and next bd down that was reported as not working.)

## Ways to pay



View and pay